

2018 ANNUAL DRINKING WATER QUALITY REPORT
PWSID #: 2660014 Tunkhannock Borough Municipal Authority

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Roger Hadsall at (570) 836-3493. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the second Tuesday of each month at 6:30 p.m. in the conference room of the office facility located at 201 W. Tioga St., Tunkhannock PA.

SOURCE(S) OF WATER:

Our water sources are:

Hill Wells 1 and 2, Tunkhannock Township

Swale Brook Well, Tunkhannock Borough

Ravine Well, Tunkhannock Township

Sunnyside Well, Tunkhannock Borough

Source Water Assessments for 3 of our 5 sources were completed in 2005 by the Environmental Resources Research institute of Pennsylvania State University and PA Department of Environmental Protection (Pa. DEP). The Assessments have stated that some of our sources are *potentially* most susceptible to agricultural contaminants, contaminants from major roadways, contaminants from low and high-density development, contamination from underground storage tanks, class 5 underground injection control wells, and contamination from a Resource Conservation and Recovery Act (RCRA) site. Overall, our sources have little to moderate risk of significant contamination. Complete reports for the wells which were assessed were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the available completed reports are available for review at the Pa. DEP Northeast Regional Office, Records Management Unit at (570) 826-2511.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2018. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level (MinRDL) - The minimum level of residual disinfectant required at the entry point to the distribution system.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter ($\mu\text{g/L}$)

ppm = parts per million, or milligrams per liter (mg/L)

ppq = parts per quadrillion, or picograms per liter

ppt = parts per trillion, or nanograms per liter

DETECTED SAMPLE RESULTS:

Chemical Contaminants								
Contaminant	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Arsenic	10	0	8	4-8	ppb	07/11/18	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium	2	2	0.286	0.138-0.286	ppm	07/11/18	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chlorine	MRDL =4	MRDLG =4	1.96	0.22-1.96	ppm	2018	N	Water additive used to control microbes
Nitrate	10	10	3.75	0.81-3.75	ppm	07/11/18	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Haloacetic Acids (5)	60	n/a	1.23	1.23	ppb	08/01/18	N	By-product of drinking water disinfection
Total Trihalomethanes (TTHMs)	80	n/a	12.3	12.3	ppb	08/01/18	N	By-product of drinking water chlorination

*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health.

Entry Point Disinfectant Residual								
Contaminant	Location ID	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine	101	0.40	1.01	1.01-2.18	ppm	2018	N	Water additive used to control microbes.
Chlorine	102	0.40	1.08	1.08-2.07	ppm	2018	N	Water additive used to control microbes.
Chlorine	103	0.46	1.01	1.01-1.99	ppm	2018	N	Water additive used to control microbes.
Chlorine	104	0.40	0.44	0.44-2.03	ppm	2018	N	Water additive used to control microbes.

Lead and Copper								
Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Units	# of Sites Above AL of Total Sites	Sample Date	Violation Y/N	Sources of Contamination
Copper	1.3	1.3	0.37	ppm	0	2017	N	Corrosion of household plumbing.

 Lead was also tested for but was not detected in any of our samples.

Radiological Contaminants									
Contaminant	Site ID	MCL in CCR Units	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Gross Alpha		15	0	4.22	3.28-4.22	ppb	7/30/15	N	Erosion of natural deposits
Combined Radium	103	5	0	0.282	0.282	pCi/L	8/22/18	N	Erosion of natural deposits
Combined Radium	101, 102, 104	5	0	2.76	0.173-2.76	pCi/L	7/30/15	N	Erosion of natural deposits

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

Information about Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Tunkhannock Borough Municipal Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Arsenic

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.